

Wiring centre description

Cartridge fuse 5 x 20 mm 2 A
 Power Supply
 Diodes
 NSB (Night Set Back reduction) function
 Thermostats connection

6. Actuators connection
7A. PL06 - pump (or boiler) control module
7B. PL07 - pump and boiler control module
8. Serial connector for PL06 and PL07 modules



1. Fuse

ERE CEX

Note: Replace the fuse only when the wiring centre is disconnected from power supply (230 V ~).

Main fuse is located under the housing cover next to power supply terminals and secures the wiring centre and the devices connected to it. Use cartridge fuses (5x20 mm) with nominal max current 2 A. To replace fuse remove the fuse holder with a flat screwdriver and pull out the fuse.



3. LED diodes

- green LED diode indicates power supply connection (230 V AC)
- orange LED diode indicates NSB function being activated

4. NSB (Night Set Back reduction) function

NSB function is activated in non-programmable Salus thermostats of the Expert NSB, HTR, BTR series via external signal. NSB 230 V signal (night-time temperature reduction) is sent via an external timer or programmable thermostat connected to the KL06 wiring centre. Non-programmable thermostats are receiving NSB signal and reducing setpoint temperature (by switching to eco mode). All thermostats have to be connected using a 4-wire cable (min. 4 x 0,75 mm², max. 4 x 1,5 mm²).

5. Thermostats connection

• Connecting EXPERT NSB, HTR or BTR series thermostats with NSB function



• Connecting a 230 V thermostat to the KL08NSB wiring centre (e.g. RT200)



Introduction

Wired KL06 230V wiring centre allows easy and quick connection of thermostats and actuators. It has a serial connector for additional modules (sold separately):

Maintaining a policy of continuous product development SALUS Controls plc reserve the right t change specification, design and materials of products listed in this brochure without prior notice.

PL06 Pump or boiler control module

Computime

www.salus-controls.com

- PL07 Pump and boiler control module
- The KL06 230V wiring centre is adapted to work with NC type actuators (normally closed) and maximum 6 thermostats.

Product Compliance

This product complies with the essential requirements and other relevant provisions of the following EU Directives: EMC 2014/30/EU, Low Voltage Directive LVD 2014/35/EU, RoHS directive 2011/65/EU. The full text of the EU Declaration of Conformity is available at the following internet address: www.saluslegal.com.

🚺 Safety information

Use in accordance to national and EU regulations. Use the device as intended, keeping it in dry condition. Product for indoor use only. Installation must be carried out by a qualified person in accordance to national and EU regulations.

Before any of operation releated to power supply (connecting wires, installing the device, etc.), make sure that KLO6 is not connected to any power source. Installation must be carried out by a qualified person. Incorrect connection of the wires may cause damage to the wiring centre. The KLO6 can not be used in conditions of water vapor condensation neither exposed to water.

Technical Information

Power Supply	230 V AC 50 Hz
Max load	2 (1) A
Outputs	Terminals for actuators (230 V)
Dimmensions [mm]	300 x 86 x 63



OR





7 A. PL06 – pump (or boiler) control module

PL06 module is used to control the pump (or boiler) using volt-free NC/COM/NO contacts. When any of thermostats connected to the KL06 230 V reports heat demand, COM/NO contacts are closing. COM/NO contacts are opening, when thermostats connected to the wiring centre will stop sending signal for heating.

Jumpers 0-15

These are used to set in minutes the delay time (overrun time). Default setting is "0".



0-15 values specify the time in minutes. E.g. when jumper is set to value "0", COM/NO output will turn off as soon as the thermostats stop calling for heat. If jumper will be set to the value "10", the module will turn off 10 min after the thermostats stop calling for heat.

Jumpers P,1,2,3,4,5,6

They are used to select the zone which turns on the module. Default setting is "P".



P - all zones start the module 1, 2, 3, 4, 5, 6 – select the specific zone which turns on the module.

PUMP CONTROL



BOILER CONTROL



Power Supply	from the KLO6 wiring centre
Max load	5 (2) A
Outputs	NO/COM/NC relay
Dimensions [mm]	60 x 80 x 20

7 B. PL07 – pump and boiler control module

PL07 module is used to control the pump and the boiler using volt-free COM/NO contacts. When any of thermostats connected to the KL06 230V reports heat demand, COM/NO contacts are closing. COM/NO contacts are opening, when thermostats connected to the wiring centre will stop sending signal for heating.

ON-OFF Delay jumper

Is used to activate the delay output for the pump and boiler. Default is "ON".



"ON" position activates the pump and boiler outputs with a delay of 3 minutes after the heating signal is supplied from any of the thermostats connected to the wiring centre. • "OFF" position causes immediate activation of the pump and boiler outputs.

ON-OFF Overrun jumper

Is used to activate the delay output for the pump when heating is satisfied. Default is "ON".

- "ON" position turns OFF the pump output with a delay of 3 minutes when all thermostats stop calling for heat. ON OFF • "OFF" position immediately turns OFF the pump output when all thermostats
- Overrui stop calling for heat.

PUMP AND BOILER CONTROL



Power Supply	from the KL06 wiring centre
Max load	5 (2) A
Outputs	2 x NO/COM relay
Dimensions [mm]	70 x 80 x 20
· · · · · · · · · · · ·	

8. Serial connector for PL06 and PL07 modules.

It provides communication between the KL06 wiring centre and the PL06/PL07 modules. KL06 wiring centre + PL06/PL07 module increases functionality and additionally makes possible to control pump and/or boiler. PL06/PL07 module is powered from the wiring centre.









Unscrew the main housing (see picture).





Remove the appropriate pices of insulation from the wires.

of the wiring centre.

installation proces). u l n 🖗 n l u





Connect the thermoelectric actuators wires.

INSTALLATION OF THE ADDITIONAL MODULE PLO6 OR PL07 ON THE EXAMPLE OF PL06 MODULE





Remove the top cover of the wiring centre.

Note: Before connecting PL06/PL07 module, disconnect the main power from the KL06 wiring centre.



- Thread the wires under the mounting belt in the back part
- ① Set includes supplementary accessories (to support





Mount the back side of the housing to the wall. When mounting on a DIN rail, open the hooks on the back of the housing.



Thread the wires through the slots in the top part of the wiring centre and connect it to the terminals.



Make sure that all the wires are properly connected, mount top cover and power up the wiring centre the green "Power" indicator LED will illuminate.

Connect the PL06 or PL07 module to the serial connector.



Make sure that all the wires are properly connected, mount top cover and power up the wiring centre the green "Power" indicator LED will illuminate.